



EU - Declaration of conformity

Manufacturer: ETI Elektroelement d.d.

Address: Obrezija 5, 1411 Izlake, SLOVENIA

Products: **NV (NH) gTr Low-voltage Fuse Links (live and insulated gripping-lugs)**
400V a.c., 100kA
Size NH 3, Types M3TTxxx* and M3TTxxx*ISG, TOP indicator
Types M3TTxxx*MI and M3TTxxx*MI/ISG, CENTRE indicator
S_n= 50kVA, 75kVA, 100kVA, 125kVA, 160kVA, 200kVA, 250kVA,
315kVA, 400kVA, 500kVA, 630kVA
***xxx = transformer nominal current ($I_n = S_n / \sqrt{3} \times U_n$)**

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The objects of the declaration described above are in conformity with the following relevant Union harmonisation legislations:

2006/95/EC

Directive of the European Parliament and of the Council of 12 December 2006 on the harmonisation of the laws of Member States relating to electrical equipment designed for use within certain voltage limits **(until 19.04.2016)**.

2014/35/EU

Directive of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits; Official Journal of the EU L96, 29/03/2014, p. 357-374 **(from 20.04.2016)**.

2011/65/EU

Directive of the European Parliament and of the Council of 8 June 2011 on the restriction of the use of certain hazardous substances in electrical and electronic equipment (recast).

Our products are constructed and manufactured based on our Quality Management System (according to DIN EN ISO 9001) in correspondence to the following standards:

Harmonized European standards:

**DIN EN 60269-1:2015-05, DIN VDE 0636-2:2014-09,
DIN VDE 0636-21:2015-03**

National standards:

VDE 0636-1:2015-05, VDE 0636-2:2014-09, VDE 0636-21:2015-03

Type test reports:

Internal test reports, Test report 2.03.02769.1.0/250...630kVA/gTr
Test reports Nr. 760349-2, 760240-1, 760319-2 / NH4a 400kVA, gTr
Test reports Nr. 760379, 760240-2, 760319-3 / NH4a 630kVA, gTr

Marking with CE:

On the product / On the packaging

Affixing of the CE-marking:

2001

Place and date:

Izlake, 01.12.2016

Manufacturer representative signature and stamp:

Viktor Martinčič, univ.dipl.ing.


ELEKTROELEMENT d.d.
IZLAKI
